



# Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows  
Rollläden · shutters  
Türen + Tore · doors  
Fassaden · curtain walling  
Baubeschläge · building hardware


## TEST CERTIFICATE NO. 19/07-A008-Z1

PfB-Internal-No. 2020-27-0350

Testing of conservatory roller shutter with reference to the test standards EN 1027 for water tightness, EN 12833 for resistance to snow load"

**Customer** Emre Al. Yapı Sanayi Tic.A.Ş.  
Adem yavuz mah. Ali yüksel sok. No:37  
Ümraniye – İstanbul

**Product Type** Power operated conservatory roller shutter with  
aluminum construction




**Product Name** Huun Rolling roof

**Dimension** Total outside dimensions (W x H) max. 3000 mm x 3000 mm

**Classification** According to test report No. 19/07-A008-B1 from March 03, 2020:

EN 1027	Water tightness	EN 12208	Class <b>6A</b>
EN 12833	Resistance to wind load		<b>60 Kg/m<sup>2</sup></b>

**Validity** Period of validity of standards



Dipl. Ing. (FH) Rüdiger Müller  
Head of Institute



Yiğit Altuğ  
Responsible Official