



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware


TEST CERTIFICATE NO. 17/12-A006-Z2

Version 1.en

PfB-Internal-No. 18/03-A134

Testing of balcony glazing with reference to the test standards EN 1026 for air permeability, EN 12211 for resistance to wind load and DIN EN 12600 for pendulum tests"

Applicant Emre Al. Yapı Sanayi Tic.A.Ş.
 Adem yavuz mah. Ali yüksel sok. No:37
 Ümraniye – İstanbul



Product type Fully glazed sliding door system with glazed panels made of double glazing.

Product name Sliding Thermal


Dimension Total outside dimensions (W x H) max. 2000 mm x 2000 mm
 Each panel dimensions (W x H) max. 495 mm x 1950 mm

Classification According to test report No. 17/12-A006-B2 from March 05, 2018:



EN 1026	Air Permeability	EN 12207	Class 1
EN 12211	Resistance to Wind Load	EN 12210	Class B1/C1
EN 12600	Impact Resistance	EN 14019	Class I2

Validity Period of validity of standards


 Dipl. Ing. (FH) Rüdiger Müller
 Head of Institute



Stephanskirchen
 March 05, 2018


 Yigit Altug
 Responsible Official

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
 AG Traunstein HRA 8871
 Lackermannweg 24, 83071 Stephanskirchen
 phG PfB Verwaltungs GmbH
 Geschäftsführer: Matthias Demmel, Rüdiger Müller
 AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0
 Telefax +49 (0) 80 36 / 67 49 47 28
 www.pfb-rosenheim.de
 info@pfb-rosenheim.de

Sparkasse Rosenheim
 Bankleitzahl 711 500 00
 Kontonummer 500 556 741
 Steuer-Nr.156/172/13009
 USt-IdNr. DE245353602

